

December 13, 2018

**FAX AND EMAIL &  
ATTACH TO CONTRACT**

**ADDENDUM NO. 1 TO  
MILLION GALLON TANKS REHABILITATION AND INTERIOR RECOATING  
TWIN HART COMMUNITY SERVICES DISTRICT  
PROJECT 200-57-0001**

**The final day, time and location for submittal of bids remain unchanged:  
Wednesday, December 19, 2018, at 3:00 p.m.**

At: Twain Harte Community Services District  
22912 Vantage Pointe Drive  
Twain Harte, California 95383

The following revisions are hereby incorporated into the Contract for the subject project:

---

Part VII, "Technical Specifications," is hereby amended as follows:

- 1) Section 09905, "Protective Coatings," Paragraph 3.09, "Coating System – Exterior Roofs and Spot Repair of Damaged Areas"; replace Paragraph 3.09.B in its entirety with the following:

*B. Included Items (Base Bid): Spot repair all areas damaged by welding or other actions associated with the project including, but not limited to: roof structure replacement, eave vent patch plates and installation of upgrade appurtenances.*

- 2) Section 13020, "Replace Roof Structure for Welded Steel Water Storage Tank," Part 3 – Execution; add the following paragraph to the end of Part 3 – Execution:

**3.04 EAVE VENT PATCH PLATES**

*Remove vent screens and associated hardware. Prepare the existing, roughly cut, corroded holes. Install cover plates on the interior side with approximately 1" lap. Plates shall be seal welded from both sides using low hydrogen electrode. Patch plates and installation shall be pursuant to API 653. Patch plates shall be ¼" thick A36 steel or applicable equivalent. Tank MG #1 has 17 vents and Tank MG #2 has 16 vents. Design roof structure to allow for variation of inside radius, including where rafters land on eave vent patch plates.*

---

All bidders shall acknowledge acceptance of this correction notice. **PLEASE FAX OR EMAIL A SIGNED COPY OF THIS SHEET, INDICATING CONFIRMATION OF RECEIPT OF THIS ADDENDUM NO. 1.** Confirmations can be faxed to (209) 586-0424 or emailed to [ttrott@twainhartecsd.com](mailto:ttrott@twainhartecsd.com). If you are unable to read the fax, you may view the Addendum at [www.twainhartecsd.com/bidding](http://www.twainhartecsd.com/bidding).



TOM TROTT  
General Manager

**ACKNOWLEDGMENT**

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date